

§ 108.489

be protected from icing and freezing, and be capable of operation within 10 seconds after activation of its controls.

(d) Each system must have at least one hose at each of the two access routes required by §108.235(f) of this part. Each hose must be reel mounted and long enough to cover any point on the helicopter deck. Each hose that discharges foam must have a nozzle that has foam stream, foam spray, and off positions.

§ 108.489 Helicopter fueling facilities.

(a) Each helicopter fueling facility must have a fire protection system that discharges one of the following agents in the amounts prescribed for the agents over the area of the fuel containment systems around marine portable tanks, fuel transfer pumps and fuel hose reels:

(1) Protein foam at the rate of 6.52 liters per minute for each square meter (.16 gallons per minute for each square foot) of area covered for five minutes.

(2) Aqueous film forming foam at the rate of 4.07 liters per minute for each square meter (.1 gallon per minute for each square foot) of area covered for five minutes.

(3) 22.5 kilograms (50 pounds) of dry chemical (B-V semi-portable) for each fueling facility of up to 27.87 square meters (300 square feet).

(b) If the fire protection system required by §108.487 of this subpart is arranged so that it covers both a helicopter fueling facility and a landing deck, the system must have the quantity of agents required by this section in addition to the quantity required by §108.487.

46 CFR Ch. I (10–1–14 Edition)

HAND PORTABLE AND SEMI-PORTABLE FIRE EXTINGUISHING SYSTEMS

§ 108.491 General.

Each hand portable and semiportable fire extinguisher on a unit must be approved under Subpart 162.028 or 162.039 of this chapter.

§ 108.493 Location.

(a) Each unit must have the hand portable and semiportable fire extinguishers prescribed in Table 108.495(a) of this subpart and installed in the locations prescribed in the table.

(b) Each portable and semi-portable fire extinguisher must be visible and readily accessible.

(c) The location, size, and number of each portable and semiportable fire extinguisher on a unit must be acceptable to the appropriate OCMI. The OCMI may require extinguishers in addition to those prescribed in Table 108.495(a) if he considers them necessary for fire protection on the unit.

(d) Each hand portable and semiportable fire extinguisher that has a nameplate which states that it is to be protected from freezing, must be located where freezing temperatures do not occur.

§ 108.495 Spare charges.

(a) Each unit must have enough spare charges for 50 percent of the hand portable fire extinguishers required under Table 108.495(a) of this subpart that are rechargeable by personnel on the unit.

(b) If a unit has extinguishers that cannot be recharged by personnel on unit, it must also have at least one spare extinguisher for each classification and variety of those extinguishers.

TABLE 108.495(a)—HAND PORTABLE FIRE EXTINGUISHERS AND SEMI-PORTABLE FIRE-EXTINGUISHING SYSTEMS

Space	Classification (see table 108.495(b))	Quantity and location
SAFETY AREAS		
Wheelhouse and control room	C-I	2 in vicinity of exit.
Stairway and elevator enclosure	None required.
Corridors	A-II	1 in each corridor not more than 150 ft (45 m) apart. (May be located in stairways.)
Lifeboat embarkation and lowering stations	None required.
Radio room	C-I	2 in vicinity of exit.

TABLE 108.495(a)—HAND PORTABLE FIRE EXTINGUISHERS AND SEMI-PORTABLE FIRE-EXTINGUISHING SYSTEMS—Continued

Space	Classification (see table 108.495(b))	Quantity and location
ACCOMMODATIONS		
Staterooms, toilet spaces, public spaces, offices, lockers, small storerooms, and pantries, open decks, and similar spaces.	None required.
SERVICE SPACES		
Galleys	B-II or C-II	1 for each 2,500 ft ² (232 m ²) or fraction thereof suitable for hazards involved.
Paint and lamp rooms	B-II	1 outside each room in vicinity of exit.
Storerooms	A-II	1 for each 2,500 ft ² (232 m ²) or fraction thereof located in vicinity of exits, either inside or outside the spaces.
Work shop and similar spaces	C-II	1 outside each space in vicinity of an exit.
MACHINERY SPACES		
Oil-fired boilers: Spaces containing oil-fired boilers, either main or auxiliary, or their fuel oil units.	B-II	2 required in each space.
Internal combustion or gas turbine propelling machinery spaces.	B-V	1 required in each space.
	B-II	1 for each 1,000 brake horsepower but not less than 2 nor more than 6 in each space.
Motors or generators of electric propelling machinery that do not have an enclosed ventilating system.	B-III	1 required in each space. See note 1.
Motors and generators of electric propelling machinery that have enclosed ventilating systems.	C-II	1 for each motor or generator.
	None required.
AUXILIARY SPACES		
Internal combustion engines or gas turbine	B-II	Outside the space containing engines or turbines in vicinity of exit.
Electric emergency motors or generators	C-II	1 outside the space containing motors or generators in vicinity of exit.
Steam driven auxiliary machinery	None required.
Trunks to machinery spaces	Do.
Fuel tanks	Do.
MISCELLANEOUS AREAS		
Helicopter landing decks	B-V	1 at each access route.
Helicopter fueling facilities	B-IV	1 at each fuel transfer facility. See note 2.
Drill floor	C-II	2 required.
Cranes with internal combustion engines	B-II	1 required.

Notes: 1. Not required where a fixed gas extinguishing system is installed.

2. Not required where a fixed foam system is installed in accordance with § 108.489 of this subpart.

TABLE 108.495(b)

	Classification: Type and size	Water liters (gallons)	Foam liters (gallons)	Carbon dioxide kilograms (pounds)	Dry chemical kilograms (pounds)	Halon 1211 kilograms (pounds)
A	II	9.5 (2½)	9.5 (2½)	2.25 (5) ³
B	I	4.7 (1¼)	1.8 (4)	0.9 (2)	1.1 (2½)
B	II	9.5 (2½)	6.7 (15)	4.5 (10)	4.5 (10) ⁵
B	III	45.5 (12)	15.8 (35)	9.0 (20).
B	IV	7.6 (20)	22.5 (50)	13.5 (30).
B	V	152 (40)	45 (100) ⁴	22.5 (50) ⁴
C	I	1.8 (4)	0.9 (2).
C	II	6.7 (15)	4.5 (10).
C	III	15.8 (35)	9.0 (20).
C	IV	22.5 (50)	13.5 (30).

NOTE: 1. Fire extinguishers are designed by type as follows: (a) "A" for fires in combustible materials such as wood. (b) "B" for fires in flammable liquids and greases. (c) "C" for fires in electrical equipment.

2. Fire extinguishers are designated by size where size "I" is the smallest and size "V" is the largest. Sizes "I" and "II" are hand-portable extinguishers and sizes "III", "IV", and "V" are semi-portable extinguishers.

3. Must be specifically approved as a type A, B, or C extinguisher.

4. For outside use, double the quantity of agent that must be carried.

5. For outside use only.